

BC Number.....

Project.....

Name & Project Address.....

BUILDING CONSENT PROCESSING SHEET

MARQUEE (BAM 112)

Building Elements	Items To Be Checked	Checked	Not Applicable	Comments Including Means of Verifying, Endorsements, Conditions & Requirements
General Information	Pim etc	Section 37: Resource Consent cert / Attached		
	Ownership Location	Property Ownership / authority / CT		
		Wind zone		
		Siting		
		Existing / proposed building(s)		
		Drains / services location		
		Site specific requirement		
		Floor area		
Facilities	Sanitary fixtures incl. accessible 0-50ppl = 1 0-80ppl = 2 + 1per 150ppl			
Timber Floors	PS1 for scaffolding			
	Flooring Material			
	Stairways or terraced seating	Landings / Handrails / Barriers		
		Slip resistance D1/AS1 table 2		
		Stair Dimensions/Pitch		
Elevations	Head clearance			
	Height of marquee			
Fire protection	Openings			
	Spread of flame Certificate			
	Egress widths Area x ppl/m ² x 0.007 = m of opening			
	Egress locations			
	Number of exits 0-500 = 2 501-1000 = 3			
	Linings / suspended fabrics / seating			
Lighting	Alarm system (over 50ppl)			
	Exit signage 0-100ppl			
	Illuminated exit signage 101 - 500ppl			
	Emergency lighting 500+ ppl			

Building consent may be issued.

Signed:

Dated:

Information supplied meets NZBC

Information incomplete does not meet NZBC

Not applicable